

BUILDING TRUST

PRODUCT DATA SHEET Sikafloor[®] Conductive Set

Earthing Kit For Electrostatic Conductive Floors

DESCRIPTION

Sikafloor[®] Conductive Set is an earthing kit to connect electrostatic conductive floor systems to ground

USES

Ground connection point for decorative and protective electrostatic conductive flooring systems. It is used in:

- Automotive facilities
- Electronic facilities and data centres

PRODUCT INFORMATION

- Pharmaceutical facilities
- Storage areas
- Warehouses

CHARACTERISTICS / ADVANTAGES

- Good mechanical resistance
- Electrostatically conductive
- Self-adhesive application allows fast and easy installation
- Economical

Packaging	10 earthing points supplied in a plastic box. Refer to current price list for packaging variations
Shelf Life	24 months from date of production
Storage Conditions	The Product must be stored in original, unopened and undamaged sealed packaging in dry conditions at temperatures between +5 °C and +30 °C. Always refer to packaging.

APPLICATION INFORMATION

Consumption

1 earthing point is able to conduct over a floor area of ~200–300 m². Longest distance of each earthing point to the next earthing point is 20 m maximum. For longer distances, additional earthing points must be provided.

BASIS OF PRODUCT DATA

All technical data stated in this Product Data Sheet are based on laboratory tests. Actual measured data may vary due to circumstances beyond our control.

ECOLOGY HEALTH AND SAFETY

For information and advice on the safe handling, storage and disposal of chemical products, users shall refer to the most recent Safety Data Sheet (SDS) containing physical, ecological, toxicological and other safety-related data.

APPLICATION INSTRUCTIONS

PRODUCT DATA SHEET Sikafloor® Conductive Set December 2022, Version 02.01 02081614004000002

SUBSTRATE QUALITY / PRE-TREATMENT

Refer to the appropriate flooring system primer Product Data Sheet.

APPLICATION

IMPORTANT

Connection of earthing points

The connection of the earthing points to the earthing ground must be carried out and approved by an electrical engineer and in accordance with any relevant local regulations.

Note: The optimum number of earthing connections depends on the local conditions and should be specified using available drawings.

- 1. When primer has cured, drill a hole: diameter 8 mm, depth >50 mm.
- 2. Remove all dust, loose and friable material around drilled hole and insert a size 8 plastic plug. The plug must be flush with the floor surface.
- 3. Screw the threaded dowel rod with a hexagonal socket into the plastic plug with an Allen key. Dowel rod must extend 16 mm above the floor.
- 4. Fully bond the copper strips (2 × 10 mm) on both sides of the hole.
- 5. Place the large (D=60 mm) washer followed by the smaller (D=30 mm) washer over the threaded dowel rod and secure with the nut (M6) so the washers are pressed onto the copper strips ensuring good contact.
- 6. Push the transparent plastic hose over the threaded dowel rod so the hose fits tightly.
- Apply the selected Sikafloor[®] conductive primer and conductive wearing finish ensuring all washers and copper tape are completely covered.
- 8. After curing of the Sikafloor[®] products, remove the transparent plastic hose.
- 9. Clean the head of the threaded dowel rod.
- 10. Fix the brass eyelet using the self-locking nut (M6) onto the threaded dowel rod.
- 11. Connect the grounding cable with the brass eyelet.

LOCAL RESTRICTIONS

Please note that as a result of specific local regulations the performance of this product may vary from country to country. Please consult the local Product Data Sheet for the exact description of the application fields.

LEGAL NOTES

The information, and, in particular, the recommendations relating to the application and end-use of Sika products, are given in good faith based on Sika's current knowledge and experience of the products when properly stored, handled and applied under normal conditions in accordance with Sika's recommendations. In practice, the differences in materials, substrates and actual site conditions are such that no warranty in respect of merchantability or of fitness for a particular purpose, nor any liability arising out of any legal relationship whatsoever, can be inferred either from this information, or from any written recommendations, or from any other advice offered. The user of the product must test the product's suitability for the intended application and purpose. Sika reserves the right to change the properties of its products. The proprietary rights of third parties must be observed. All orders are accepted subject to our current terms of sale and delivery. Users must always refer to the most recent issue of the local Product Data Sheet for the product concerned, copies of which will be supplied on request. It may be necessary to adapt the above disclaimer to specific local laws and regulations. Any changes to this disclaimer may only be implemented with permission of Sika® Corporate Legal in Baar.

Sika Pakistan (Pvt.) Limited

141-CCA Phase IV, DHA Lahore Punjab 54792 Pakistan phone: +92 42 3569 4266 - 67 fax: +92 42 3569 4268 http://pak.sika.com/

PRODUCT DATA SHEET

Sikafloor® Conductive Set December 2022, Version 02.01 020816140040000002 SikafloorConductiveSet-en-PK-(12-2022)-2-1.pdf



BUILDING TRUST